

2/22/2021

A.P. State Disaster Response and Fire Services Department

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**  
**Annual Periodical Renewal Fire Certificate**

From:  
Director  
State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

To:  
District Educational Officer,  
GVMC,VISHAKAPATANAM.

**File No: 16909/VSP/MSB/2021, Date:22/02/2021**  
**Occupancy NoC RC Number: 7422/VSP/MSB/2019**

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Multi Storeyed Building of SASI EDUCATIONAL SOCIETY, represented by , D.NO. 7-42-82, SANGIVALASA(V),BHEEMUNIPATANAM,GVMC,VISHAKAPATANAM. - Regarding.

- Ref: 1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.  
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.  
3. This Office NOC for Occupancy Rc No. 7422/VSP/MSB/2019, Dt.04/06/2019  
4. Renewal NOC For Occupancy 7422/VSP/MSB/2019, Dt.04/06/2019  
5. Online Application for Renewal NOC of SASI EDUCATIONAL SOCIETY, D.NO. 7-42-82, SANGIVALASA(V),BHEEMUNIPATANAM,GVMC,VISHAKAPATANAM. - Inspection report called for Regarding.  
6. Online Inspection Report submitted by Officers of this Department on 22-02-2021.

<< 0 >>

The Management of SASI EDUCATIONAL SOCIETY, represented by , D.NO. 7-42-82, SANGIVALASA(V),BHEEMUNIPATANAM,GVMC,VISHAKAPATANAM. has requested to issue Annual Periodical Fire Certificate for period 2020-2021 duly remitting the Fire Precautionary fee for Rs.403000/- vide challan No. 40176989982020,, Dated 17/02/2021 at sbi, VISHAKAPATANAM.

**SASI EDUCATIONAL SOCIETY**

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.  
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Multi Storeyed Building.  
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **SASI EDUCATIONAL SOCIETY, D.NO. 7-42-82, SANGIVALASA(V),BHEEMUNIPATANAM,GVMC,VISHAKAPATANAM.,** subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

202.83.28.165/noc/home/initial\_noc\_7/102123

**PRINCIPAL**  
**SASI E.M. HIGH SCHOOL**  
Kadakatla, TADEPALLIGUDEM  
West Godavari Dt. Pin : 534 101

**For SASI EDUCATIONAL SOCIETY**

**Secretary cum Correspondent**

1/2

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 14/06/2020 to 13/06/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

**Recommended:**

1. This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
2. This Renewal NOC is valid for five years only and it is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.169, Home (Prisons & Fire Service) Department. Dt. 19-12-2019. Two months before expire of this No Objection Certificate.
3. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided by the building as per Occupancy NOC at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire.
4. The Renewal NOC issued based on Inspection Committee report.



16909/VSP/MSB/2021

Your Sincerely,

*[Handwritten Signature]*

Director

State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

Copy to SASI EDUCATIONAL SOCIETY, D.NO. 7-42-82,  
SANGIVALASA(V),BHEEMUNIPATANAM,GVMC,VISHAKAPATANAM.  
Copy to Chief Office for Record Purpose  
Copy to Regional Fire Officer Concerned  
Copy to District Fire Officer Concerned  
Copy to Assistant District Fire Officer Concerned

202.83.28.165/home.html#final\_noc\_1/102123

PRINCIPAL  
**SASI E.M. HIGH SCHOOL**  
Kadakatta, TADEPALLIGUDEM  
West Godavari Dt. Pin : 534 101

For SASI EDUCATIONAL SOCIETY

2/2

*[Handwritten Signature]*  
Secretary cum Correspondent